NOTES:

- CURRENT STANDARD DETAIL AT CITY ENGINEERING DIVISION SHALL PREVAIL.
- 2. CROWN TO BE ROUNDED WITH NO SHARP GRADE BREAKS.
- 3. MINIMIZE VISIBLE EXPOSED GROUT AT COBBLE JOINTS.
- 4. SURFACE OF COBBLE FIELD TO BE SMOOTH AND FLAT TO GRADE WITHOUT VARIATION IN HEIGHT OF INDIVIDUAL COBBLES.
- 5. COBBLES WITH BREAKS OR FRACTURES ARE NOT ALLOWED.
- 6. ROCK SHALL BE 'SATURATED SURFACE MOIST' (SSM) PRIOR TO PLACEMENT.
- 7. CONCRETE MORTAR BED SHALL HAVE A CEMENT RATIO PER CUBIC YARD OF CONCRETE OF NOT LESS THAN 564 POUNDS; SLUMP MAX. OF 3"; AGGREGATE SIZE ½" MAXIMUM.
- 8. INTEGRAL COLOR ADMIXTURE: CHROMIX, ADOBE TAN, #C-21 BY L.M. SCOFIELD.

